

ISO 14644 Certificates

ZERTIFIKAT ♦ CERTIFICATE ♦ CERTIFICADO ♦ CERTIFICAT



CERTIFICATE

TÜV SÜD Industrie Service GmbH herewith confirms the company

Zhejiang Biorear Biotechnology Co., Ltd.

that the **Injection Moulding Workshop at No.3535, Linggongtang Road, Nanhu district, Jiaxing, Zhejiang, China**

achieved the cleanroom class 8 according to the Guideline DIN EN ISO 14644-1.

TÜV SÜD Industrie Service GmbH herewith certifies according to DIN EN ISO 14644 the compliance of the cleanroom with the user requirements as per DIN EN ISO 14644 part 1 and 3.

The characteristics had been examined by measurements and evaluations.

The certificate is restricted to:

- Airborne particulate cleanliness
- Room difference pressure
- Temperature and humidity

Certificate No.: 3456832-00
Report No.: 21.05.5010406382.001
Valid through: May 2022


Dipl.-Biol. Katrin Hartmann

Berlin, 02.06.2021

TÜV SÜD Industrie Service GmbH
Wittestraße 30, Haus L
13509 Berlin
Germany

杭州致科检测技术有限公司
Hangzhou Zhike Testing Technology Co., Ltd

证明 Certificate

杭州致科检测技术有限公司
Hangzhou Zhike Testing Technology Co., Ltd confirms the company
浙江博锐生物科技有限公司
Zhejiang Biorear Biotechnology Co., Ltd.

位于浙江省嘉兴市南湖区大桥镇兴业路 1099 号 B 生产厂房
That the Production plant B, No.1099 Xingye Road, Daqiao Town, Nanhu District, Jiaxing, Zhejiang, China

根据 DIN EN 认证指南 ISO 14644-1。十万级生产车间(第三车间、第四车间、第五车间)达到洁净度 8 级。

100,000-Level Production Workshop(Workshop 3, Workshop 4, Workshop 5) Achieved the cleanroom class 8 according to the Guideline DIN EN ISO 14644-1.

杭州致科检测技术有限公司根据 DIN EN 认证 ISO 14644 洁净室符合 DIN EN ISO 14644 第 1 部分和第 3 部分的用户要求。

Hangzhou Zhike Testing Technology Co., Ltd certifies according to DIN EN ISO 14644 the Compliance of the cleanroom with the user requirements as per DIN EN ISO 14644 Part 1 and 3

这些特征已经过测量和评估进行了检查。

The characteristics had been examined by measurements and evaluations.

证书仅限于:

The certificate is restricted to:

- 空气洁净度
- Airborne particulate cleanliness
- 房间压差
- Room difference pressure
- 温度和湿度
- Temperature and humidity

证书编号: ZKJC260102-01

Certificate No: ZKJC260102-01

报告编号: ZKJC260102-01

Report No: ZKJC260102-01

日期: 2026 年 1 月

Date of Jan 2026



地址: 浙江省杭州市西湖区振华路 195、197、199 号 405 室 电话: 0571-85119703

No. 405, 195, 197 and 199, Zhenhua Road, Xihu District, Hangzhou, Zhejiang

ISO 14644 Certificates

杭州致科检测技术有限公司
Hangzhou Zhike Testing Technology Co.,Ltd

证明 Certificate

杭州致科检测技术有限公司
Hangzhou Zhike Testing Technology Co.,Ltd confirms the company
浙江博毓生物科技有限公司
Zhejiang Biorear Biotechnology Co.,Ltd.
位于浙江省嘉兴市南湖区大桥镇兴业路 1099 号 B 生产厂房
That the Production plant B, No.1099 Xingye Road, Daqiao Town, Nanhu District, Jiaxing,
Zhejiang, China

根据 DIN EN 认证指南 ISO 14644-1。万级生产车间(第一车间、第二车间)达到洁净度 7 级。

10,000-Level Production Workshop(Workshop 1, Workshop 2)Achieved the cleanroom class7 according to the Guideline DIN EN ISO 14644-1.

杭州致科检测技术有限公司根据 DIN EN 认证 ISO 14644 洁净室符合 DIN EN ISO 14644 第 1 部分和第 3 部分的用户要求。

Hangzhou Zhike Testing Technology Co.,Ltd certifies according to DIN EN ISO 14644 the Compliance of the cleanroom with the user requirements as per DIN EN ISO 14644 Part1 and 3

这些特征已经通过测量和评估进行了检查。

The characteristics had been examined by measurements and evaluations.

证书仅限于：

The certificate is restricted to:

- 空气洁净度
- Airborne particulate cleanliness
- 房间压差
- Room difference pressure
- 温度和湿度
- Temperature and humidity

证书编号：ZKJC260102-02

Certificate No: ZKJC260102-02

报告编号：ZKJC260102-02

Report No: ZKJC260102-02

日期：2026 年 1 月

Date of Jan 2026



地址：浙江省杭州市西湖区振华路 195、197、199 号 405 室 电话：0571-85119703

No. 405, 195, 197 and 199, Zhenhua Road, Xihu District, Hangzhou, Zhejiang

杭州致科检测技术有限公司
Hangzhou Zhike Testing Technology Co.,Ltd

证明 Certificate

杭州致科检测技术有限公司
Hangzhou Zhike Testing Technology Co.,Ltd confirms the company
浙江博毓生物科技有限公司
Zhejiang Biorear Biotechnology Co.,Ltd.
位于浙江省嘉兴市南湖区大桥镇兴业路 1099 号 B 生产厂房
That the Production plant B, No.1099 Xingye Road, Daqiao Town, Nanhu District, Jiaxing,
Zhejiang, China

根据 DIN EN 认证指南 ISO 14644-1。滤芯车间达到洁净度 8 级。

Filter shop Achieved the cleanroom class8 according to the Guideline DIN EN ISO 14644-1.

杭州致科检测技术有限公司根据 DIN EN 认证 ISO 14644 洁净室符合 DIN EN ISO 14644 第 1 部分和第 3 部分的用户要求。

Hangzhou Zhike Testing Technology Co.,Ltd certifies according to DIN EN ISO 14644 the Compliance of the cleanroom with the user requirements as per DIN EN ISO 14644 Part1 and 3

这些特征已经通过测量和评估进行了检查。

The characteristics had been examined by measurements and evaluations.

证书仅限于：

The certificate is restricted to:

- 空气洁净度
- Airborne particulate cleanliness
- 房间压差
- Room difference pressure
- 温度和湿度
- Temperature and humidity

证书编号：ZKJC260102-03

Certificate No: ZKJC260102-03

报告编号：ZKJC260102-03

Report No: ZKJC260102-03

日期：2026 年 1 月

Date of Jan 2026



地址：浙江省杭州市西湖区振华路 195、197、199 号 405 室 电话：0571-85119703

No. 405, 195, 197 and 199, Zhenhua Road, Xihu District, Hangzhou, Zhejiang